




Certificate No. 152  
ISO 9001: 2000

## PS440 Heatsink



Length	C/W Bare	C/W Ano
50	0.48	0.43
100	0.295	0.263
150	0.238	0.213
200	0.2	0.18
250	0.193	0.173
300	0.18	0.161

Large area heat source  
Thermal data for guideline only

**GD Rectifiers Ltd.** Bentley House, 2 William Way, Burgess Hill, West Sussex RH15 9AG.

**Tel: 01444 243452 Fax: 01444 870722**

**E-Mail: [enquiries@gdrectifiers.co.uk](mailto:enquiries@gdrectifiers.co.uk) Web Site: [www.gdrectifiers.co.uk](http://www.gdrectifiers.co.uk)**